



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-01	Sample Name: Rm 11 DF Sampled: 3/13/20 8:20						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-02	Sample Name: Rm 13 DF Sampled: 3/13/20 8:22						Matrix: Water
†Lead	1030	EPA 200.9	10	ppb	2	20 ppb	03/20/20 15:44
0077067-03	Sample Name: Rm 14 Sink Sampled: 3/13/20 8:24						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-04	Sample Name: Rm 18 DF Sampled: 3/13/20 8:26						Matrix: Water
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	03/20/20 15:44
0077067-05	Sample Name: Rm 15 FA Sampled: 3/13/20 8:28						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-06	Sample Name: Kitchen Wash Sink Sampled: 3/13/20 8:30						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-07	Sample Name: Kit. Hand Wash Sink Sampled: 3/13/20 8:32						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-08	Sample Name: Rm 42 Left Sink Sampled: 3/13/20 8:34						Matrix: Water
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	03/20/20 15:44
0077067-09	Sample Name: Rm 42 Right Sink Sampled: 3/13/20 8:38						Matrix: Water
†Lead	1030	EPA 200.9	12	ppb	2	20 ppb	03/20/20 15:44
0077067-10	Sample Name: Girls RR Office 1 Sampled: 3/13/20 8:40						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-11	Sample Name: Kitchen RR Sink Sampled: 3/13/20 8:42						Matrix: Water
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	03/20/20 15:44
0077067-12	Sample Name: 6th Gr Girls RR Sink Sampled: 3/13/20 8:44						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-13	Sample Name: 6th Gr Stuff RR Sink Sampled: 3/13/20 8:46						Matrix: Water
†Lead	1030	EPA 200.9	12	ppb	2	20 ppb	03/20/20 15:44
0077067-14	Sample Name: Rm 9 DF Sampled: 3/13/20 8:48						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-15	Sample Name: Rm 9 FA Sampled: 3/13/20 8:50						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-16	Sample Name: SE GIRLS RR Sink Sampled: 3/13/20 8:52						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-17	Sample Name: Rm 16 DF Sampled: 3/13/20 8:53						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-18	Sample Name: Rm 16 FA Sampled: 3/13/20 8:54						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	2	20 ppb	03/20/20 15:44
0077067-19	Sample Name: Rm 7 FA Sampled: 3/13/20 8:56						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	2	20 ppb	03/20/20 15:44
0077067-20	Sample Name: Rm 11 FA Sampled: 3/13/20 8:57						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-21	Sample Name: 8th DF WEST Sampled: 3/13/20 9:00						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-22	Sample Name: Rm 38 RIGHT - "South Wall R" labeled on bottle Sampled: 3/13/20 9:02						Matrix: Water
†Lead	1030	EPA 200.9	29	ppb	4	20 ppb	03/20/20 15:44 MCLE
0077067-23	Sample Name: Rm 38 MIDDLE - "South Wall M" labeled on bottle Sampled: 3/13/20 9:03						Matrix: Water
†Lead	1030	EPA 200.9	46	ppb	2	20 ppb	03/20/20 15:44 MCLE
0077067-24	Sample Name: Rm 38 LEFT - "South Wall L" labeled on bottle Sampled: 3/13/20 9:05						Matrix: Water
†Lead	1030	EPA 200.9	11	ppb	2	20 ppb	03/20/20 15:44
0077067-25	Sample Name: Near Rm 36 MENS RR Sampled: 3/13/20 9:07						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-26	Sample Name: Rm 37 Sampled: 3/13/20 9:09						Matrix: Water
†Lead	1030	EPA 200.9	7	ppb	2	20 ppb	03/20/20 15:44
0077067-27	Sample Name: Rm 35 LEFT SOUTH WALL Sampled: 3/13/20 9:10						Matrix: Water
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	03/20/20 15:44
0077067-28	Sample Name: Rm 35 MIDDLE NORTH WALL Sampled: 3/13/20 9:12						Matrix: Water
†Lead	1030	EPA 200.9	13	ppb	2	20 ppb	03/20/20 15:44
0077067-29	Sample Name: Rm 35 LEFT N. WALL Sampled: 3/13/20 9:14						Matrix: Water
†Lead	1030	EPA 200.9	25	ppb	2	20 ppb	03/20/20 15:44 MCLE
0077067-30	Sample Name: Rm 35 MIDDLE S. WALL Sampled: 3/13/20 9:16						Matrix: Water
†Lead	1030	EPA 200.9	29	ppb	2	20 ppb	03/20/20 15:44 MCLE



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-31	Sample Name: Rm 32 Sampled: 3/13/20 9:18						Matrix: Water
†Lead	1030	EPA 200.9	21	ppb	2	20 ppb	03/20/20 15:44 MCLE
0077067-32	Sample Name: Rm 33 Sampled: 3/13/20 9:20						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	2	20 ppb	03/20/20 15:44
0077067-33	Sample Name: South Gym DF Sampled: 3/13/20 9:23						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-34	Sample Name: Girls Locker Rm LEFT Sampled: 3/13/20 9:25						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-35	Sample Name: Girls Locker Rm RIGHT Sampled: 3/13/20 9:29						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-36	Sample Name: Rm 31 Sampled: 3/13/20 9:30						Matrix: Water
†Lead	1030	EPA 200.9	104	ppb	8	20 ppb	03/20/20 15:44 MCLE
0077067-37	Sample Name: 8th GRADE EAST DF Sampled: 3/13/20 9:33						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-38	Sample Name: Rm 30 South Wall Sampled: 3/13/20 9:35						Matrix: Water
†Lead	1030	EPA 200.9	2	ppb	2	20 ppb	03/20/20 15:44
0077067-39	Sample Name: 8th GRADE BOYS RR Sampled: 3/13/20 9:37						Matrix: Water
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	03/20/20 15:44
0077067-40	Sample Name: Rm 17 DF Sampled: 3/13/20 9:38						Matrix: Water
†Lead	1030	EPA 200.9	6	ppb	2	20 ppb	03/20/20 15:44



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T

Molalla River School District

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-41	Sample Name: SE BOYS RR 2 Sampled: 3/13/20 9:40					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-42	Sample Name: Rm 8 FA Sampled: 3/13/20 9:41					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-43	Sample Name: 6th Boy RR 1 Sampled: 3/13/20 9:42					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-44	Sample Name: 6th Boy RR 3 Sampled: 3/13/20 9:44					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-45	Sample Name: SE Boys 1 Sampled: 3/13/20 9:45					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-46	Sample Name: 6th Boys RR 2 Sampled: 3/13/20 9:46					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-47	Sample Name: C Coop Rm FA Sampled: 3/13/20 9:48					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-48	Sample Name: Rm 6 FA Sampled: 3/13/20 9:50					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-49	Sample Name: Rm 6 DF Sampled: 3/13/20 9:52					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-50	Sample Name: Girls RR Office 3 Sampled: 3/13/20 8:00					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-51	Sample Name: Girls RR Office 2 Sampled: 3/13/20 8:02						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-52	Sample Name: Comp LAB 19 DF Sampled: 3/13/20 8:04						Matrix: Water
†Lead	1030	EPA 200.9	8	ppb	2	20 ppb	03/20/20 15:44
0077067-53	Sample Name: Comp LAB FA Sampled: 3/13/20 8:06						Matrix: Water
†Lead	1030	EPA 200.9	22	ppb	2	20 ppb	03/20/20 15:44 MCLE
0077067-54	Sample Name: Library Office Sampled: 3/13/20 8:08						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-55	Sample Name: Conference Rm - "Office" labeled on bottle Sampled: 3/13/20 8:10						Matrix: Water
†Lead	1030	EPA 200.9	5	ppb	2	20 ppb	03/20/20 15:44
0077067-56	Sample Name: Staff Mens RR Office Sampled: 3/13/20 8:12						Matrix: Water
†Lead	1030	EPA 200.9	4	ppb	2	20 ppb	03/20/20 15:44
0077067-57	Sample Name: Rm 12 FA Sampled: 3/13/20 8:14						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-58	Sample Name: Rm 109 Sampled: 3/13/20 8:16						Matrix: Water
†Lead	1030	EPA 200.9	5	ppb	2	20 ppb	03/20/20 15:44
0077067-59	Sample Name: SE Boys RR 3 Sampled: 3/13/20 8:18						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-60	Sample Name: Boys RR (Near Office) RIGHT Sampled: 3/13/20 7:30						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44



**Professional
Laboratory
Services**

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T **Molalla River School District**

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-61	Sample Name: Boys RR (Office) LEFT Sampled: 3/13/20 7:31						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-62	Sample Name: 6th Hall DF Sampled: 3/13/20 7:32						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-63	Sample Name: Boys RR Office MIDDLE Sampled: 3/13/20 7:33						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-64	Sample Name: D.F. Outside Rm. 26 Sampled: 3/13/20 7:35						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-65	Sample Name: Womens Office RR Sink Sampled: 3/13/20 7:36						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-66	Sample Name: Office Hall DF Sampled: 3/13/20 7:38						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-67	Sample Name: Staff RR Sink Sampled: 3/13/20 7:42						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-68	Sample Name: Rm 24 Sampled: 3/13/20 7:45						Matrix: Water
†Lead	1030	EPA 200.9	78	ppb	8	20 ppb	03/20/20 15:44 MCLE
0077067-69	Sample Name: Boys Locker Rm RIGHT Sampled: 3/13/20 7:46						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-70	Sample Name: South Gym D.F. Sampled: 3/13/20 7:47						Matrix: Water
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44



Professional Laboratory Services

13035 SW Pacific Hwy
Tigard, OR 97223
Tel.: (503) 639-9311 Fax: (503) 684-1588

ANALYSIS REPORT

Reported: 03/25/2020
Received: 03/17/2020
Sampled By: Tony Tiano & Ric Dettwyler
Work Order: 0077067

C L I E N T Molalla River School District

Attn: Tony Tiano
412 S Sweigle Ave
Molalla OR, 97038
Phone: (503) 915-5248

Project:

Project # : -
Sample Type :

Sampling Location: Molalla River Middle School

Lab Number

	Code	Method	Result	Units	MRL	EPA MCL*	Analysis Date/ Time
0077067-71	Sample Name: Rm 20 F.A. Sampled: 3/13/20 7:50					Matrix: Water	
†Lead	1030	EPA 200.9	11	ppb	2	20 ppb	03/20/20 15:44
0077067-72	Sample Name: Rm 21 F.A. Sampled: 3/13/20 7:51					Matrix: Water	
†Lead	1030	EPA 200.9	11	ppb	2	20 ppb	03/23/20 15:39
0077067-73	Sample Name: Rm 22 F.A. Sampled: 3/13/20 7:52					Matrix: Water	
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	03/20/20 15:44
0077067-74	Sample Name: Rm 22 DF Sampled: 3/13/20 7:53					Matrix: Water	
†Lead	1030	EPA 200.9	3	ppb	2	20 ppb	03/20/20 15:44
0077067-75	Sample Name: Cafe DF Sampled: 3/13/20 7:55					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44
0077067-76	Sample Name: Boys Locker Rm LEFT Sampled: 3/13/20 7:56					Matrix: Water	
†Lead	1030	EPA 200.9	ND	ppb	2	20 ppb	03/20/20 15:44

MCLE This analyte exceeds the MCL limit.

ND = None detected at the MRL **MRL** = Minimum Reporting Limit

MCL = Maximum Contamination Limit

†All procedures for this analysis are in accordance with NELAP standards.

* The EPA MCL for Lead in Public Drinking Water Systems is 15 ppb. For school, daycare, or non-residential building testing the EPA recommends outlets be taken out of service if the lead level exceeds 20 ppb; this is a maximum contamination level for lead in samples based on a 250 mL first-draw sample, exceedences require remediation or further sampling. This is not an acceptance level for health based exposure.

Approved by:

Adriana Gonzalez-Gray
Laboratory Director